



May 30, 2024

Mr. Gregory Rondeau, Chairman
355 East Central Street
Franklin, MA 02038

**Re: Nylah Crossing LLC, 240 East Central Street & 9 Lewis Street
Site Plan Peer Review**

Dear Mr. Rondeau:

BETA Group, Inc. is pleased to provide engineering peer review services for the proposed project entitled "**Site Plan Review 240 East Central Street & 9 Lewis Street**" located at 240 East Central Street in Franklin, Massachusetts. This letter is provided to update BETA's findings, comments, and recommendations.

Basis of Review

The following documents were received by BETA and will form the basis of the review:

- Plans (13 sheets) entitled: "**MPDC_Plan Set - 240 E Central St, Franklin MA 2024.05.23**", dated May 23, 2024, prepared by MP Design Consultants Inc. of Southborough, MA stamped by Carlos Ferrera, MA PE #4143.
- Stormwater Management Report prepared for Nylah Crossing LLC dated May 23, 2024, prepared by MP Design Consultants Inc. of Southborough, MA stamped by Carlos Ferreira, MA PE #41426.
- Site Plan Review Application, including:
 - Form P – 240 East Central Street
 - Form P – 9 Lewis Street
 - Certificate of Ownership

Review by BETA included the above items along with the following, as applicable:

- Site Visit
- **Zoning Chapter 185 From the Code of the Town of Franklin**, current through July 2021
- **Zoning Map of the Town of Franklin, Massachusetts**, attested to October 7, 2020
- **Stormwater Management Chapter 153 From the Code of the Town of Franklin**, Adopted May 2, 2007
- **Subdivision Regulations Chapter 300 From the Code of the Town of Franklin**, current through March 8, 2021
- **Wetlands Protection Chapter 181 From the Code of the Town of Franklin**, dated August 20, 1997
- **Town of Franklin Best Development Practices Guidebook**, dated September 2016

1.0 SITE AND PROJECT DESCRIPTION

The project site includes two lots identified as Assessors Map 285 Parcels 66 and 68, with a total area of 34,500± square feet located at 240 East Central Street and 9 Lewis Street in the Town of Franklin (the “Site”). The Site is located within the Commercial 1 zoning district. The adjacent lot to the west is Taj Estates, a recently permitted multi-family housing development at 230 East Central Street. The 2 single family dwellings to the east along Lewis Street are also located in the Commercial 1 zoning district. The lots to the south are in the Single-Family IV zoning district with a single-family dwelling at 29 Lewis Street located just off the southeast corner of the parcel. The Site is located within the limits of the Water Resource District.

The existing Site is the location of two single-family residential dwellings at 240 East Central Street and 9 Lewis Street. The 240 East Central property was formerly used as a daycare facility. The proposed development is to combine the lots and raze the existing structures to construct two buildings, Building “A” and Building “B” located on the eastern and western sides of the Site, respectively. Building A will be a multi-story, mixed-use structure with a footprint area of 5,940± sq. ft. that will provide 6 housing units. Building B will be a multi-story, mixed-use structure with a footprint area of 8,326± sq. ft. that will provide 8 housing units and 406 square feet of commercial use on the first floor.

Access to the Site is proposed via a new one-way driveway beginning at East Central Street at the north side of the Site, continuing south between the two buildings, then ending at Lewis Street in the southeast corner of the Site. Associated Site features include curbing, sidewalk, landscaping, parking areas, residential garages, fencing, and utilities (water, sanitary sewer, gas, electric). Stormwater management is proposed via a new closed drainage system consisting of catch basins and manholes which will convey stormwater runoff to one large subsurface infiltration system and four smaller subsurface infiltration systems.

No wetland resource areas are located within or in the vicinity of the Site. The Site is not located in a FEMA mapped 100-year floodplain or an NHESP-mapped estimated habitat of rare or endangered species. The project is in the Water Resource District which is the Zone II of a public water supply well. NRCS soil maps indicate that underlying soils are Sudbury fine sandy loam with a hydrologic soil group rating (HSGR) of B (moderate infiltration potential) or urban land with no assigned HSGR.

2.0 WAIVERS

No waiver requests are noted in the submission.

3.0 GENERAL REVIEW COMMENTS

G1. *Provide information on the existing sewer easement located along the southern side of the Site. Confirm that proposed site features, including drainage, gas, and water utilities as well as paving and the southwestern building corner, can be constructed within this easement.* MPD: No response

BETA2: No information has been provided. BETA notes proposed site features within the easement are now limited to paving, curbing, and fencing.

4.0 TOWN OF FRANKLIN ZONING REQUIREMENTS

The project is subject to the Town of Franklin zoning regulations outlined under Chapter 185. Review comments related to the zoning bylaw are provided in the following sections.

The project proposes a Mixed Use consisting of commercial and residential uses and is located within the Commercial I (CI) district. Both proposed buildings have greater than 3 housing units.

Multifamily or apartment residential uses with four or more housing units are permitted in the CI district subject to the requirement that lot area must be at least 25% greater than that required for a single-family dwelling and no more than one dwelling unit per 2,250 Sq. Ft. of lot area is permitted. The project will meet both of these requirements.

Certain types of commercial uses are allowed in the CI district; several categories of commercial uses are not allowed or require a special permit.

Z1. *Clarify the nature of the proposed commercial uses and confirm it will be a permitted use.*

MPD: This property is zoned as Commercial I and in accordance with the town of Franklin's bylaw Chapter 185 - Zoning Attachment 8 the accessory use of Professional Office, Studio is deemed a permitted use.

BETA2: Information provided. BETA defers to the Board to determine if any conditions or restrictions are required to ensure the proposed commercial use remains as a permitted use in the future.

SCHEDULE OF LOT, AREA, FRONTAGE, YARD AND HEIGHT REQUIREMENTS (§185 ATTACHMENT 9)

The project will comply with dimensional requirements for lot area, frontage, lot width, lot depth front yard, building height, building coverage, and maximum impervious coverage.

Additional requirements are in place for required side yard. Per §185 Attachment 9, Note 14, the 10-foot side setback is required on one side of the lot; if lot abuts a residential district, a 20-foot setback is required on the abutting side. The lot abuts a residential district to the south only. Ten-foot and 25-foot side yards are provided on the shared lot lines with #244 East Central Street. A 6.16' setback is provided along the westerly property line.

Z2. *BETA defers to the zoning compliance officer to determine if a 20-foot setback is required along the westerly property line.*

MPD: This property is zoned as Commercial I and in accordance with the town of Franklin's bylaw Chapter 185 - Zoning Attachment 9 the minimum side yard dimension is 0'. The abutting property is also zone Commercial I and not residential, avoiding the enactment of a 20' setback.

BETA2: BETA defers this issue and the determination of which lot lines qualify as side vs. rear to the Zoning Compliance Officer.

PARKING, LOADING AND DRIVEWAY REQUIREMENTS (§185-21)

Refer to Traffic Assessment section below.

SIDEWALKS (§185-28) AND CURBING (§185-29)

The project is located within the Commercial I zoning district and is thus subject to §185-28. An existing sidewalk is present along East Central Street and the project proposes to reconstruct the portions of the sidewalk that will be impacted by the new driveway entrance. No sidewalk is proposed along Lewis Street.

Proposed curbing includes vertical granite curb at the East Central Street driveway entrance, Cape Cod Berm along Lewis Street, and precast concrete curb around parking areas and along sidewalks within the Site.

- Z3. *Depict existing and proposed sidewalk width on the plans. The sidewalk along the frontage must be at least 6 feet in width. BETA defers to the Town if a smaller width may be appropriate to match the existing sidewalk, if needed (§185-28).*

MPD: V-101 Existing Conditions and C-102 Layout and Materials Plan have been updated to include the width of the sidewalks. The sidewalk to the right of the entrance where the proposed sidewalk transitions into the existing sidewalk is 5.4' and the proposed sidewalk is 5'.

BETA2: BETA recommends matching the width of the existing sidewalk within the right-of-way and defers this matter to the Board.

- Z4. *BETA defers to the Planning Board to confirm the installation of sidewalks on Lewis Street is not useful (§185-28).*

MPD: The proposed sidewalk on Lewis Street has been removed from C-102 Layout and Materials Plan.

BETA2: No further comment.

- Z5. *BETA defers to the Town whether vertical granite curb should be provided at the Lewis Street driveway egress (§185-29) and notes that the existing edge treatment along the roadway is Cape Cod berm.*

MPD: Plans will be updated to reflect the decision of the Town of Franklin.

BETA2: BETA defers this issue to the Planning Board.

SITE PLAN AND DESIGN REVIEW (§185-31)

The project has been submitted for Site Plan Review and is required to conform to the requirements of this section. The submission is in compliance with this section except as noted below:

- Z6. *Provide note that all plantings shall come from the Best Development Practices Guidebook (§185-31.C.(3).(k)).*

MPD: All planting shall come from the Best Development Practice Guidebook.

BETA2: Note has not been added to the landscaping plan nor had the designer confirmed that proposed plantings are from the list. Comment remains.

- Z7. *Indicate if site lighting is proposed and provide photometric plan if applicable (§185-31.C.(3).(l)).*

MPD: Scone lighting will be used to reduce potential disruption for abutting properties. A finalized lighting and photometric plan will be provided and added to the plan set at a later date.

BETA2: Lighting information will be reviewed upon receipt.

- Z8. *Provide sight line information at exit to Lewis Street (§185-31.C.(3).(t)).*

MPD: Sight line information has been added to C-102 Layout and Materials Plan.

BETA2: Comment addressed.

LANDSCAPING AND SCREENING (§185-35)

Refer to Landscape and Grading section below.

WATER RESOURCES DISTRICT (§185-40)

The Site is located within the Town of Franklin Water Resources District and a Zone II Wellhead Protection Area. The project does not include any use that would be prohibited in this district. Refer to the Stormwater Management section below relating to proposed artificial recharge for impervious areas.

INCLUSIONARY ZONING (§185-51)

The project proposes a multifamily development with 10 or more housing units and is therefore required to address affordable housing requirements (§185-51.C.(1)).

Z9. *Provide information on compliance with the required number of inclusionary units per (§185-31.C.(F)).*

MPD: Two (2) of the fourteen (14) units will be allocated to affordable housing as required. Planning Board to decide on the exact units.

BETA2: Comment addressed.

5.0 TRAFFIC ASSESSMENT AND IMPACT

The Applicant provided has not provided a traffic impact report or traffic study. The project is anticipated to generate an increase in daily trips compared to existing conditions due to the proposed multifamily housing and commercial uses.

GENERAL TRAFFIC COMMENTS

T1. *The Planning Board should discuss whether a Traffic Impact Analysis is warranted for this project.*

MPD: Traffic engineer to provide traffic analysis at a later date.

BETA2: Traffic information will be reviewed upon receipt.

T2. *Provide detail for typical pavement cross section with proposed materials and thickness of each pavement/subbase layer.*

MPD: Pavement cross section detail is on sheet C-107 Construction Details.

BETA2: Information provided. BETA defers to the design engineer to confirm the suitability of the proposed materials/structure. No further comment.

SITE ACCESS AND CIRCULATION

Access to the Site is proposed via a new curb cut and driveway entrance connecting to East Central Street in the north. The existing residential driveway in this area will be removed. The proposed entrance will connect to a one-way driveway continuing south through the Site and then east towards Lewis Street. A new driveway egress is proposed connecting to Lewis Street in the southeast corner of the Site.

The proposed driveway will connect to a small parking area in the northwest as well as a series of residential garages for the western building. A sidewalk is proposed along the east side of the driveway and will connect to the sidewalk along East Central Street.

Access to residential garages for the eastern building will be provided via four new residential driveways connecting directly to Lewis Street to the east. The existing residential driveway along Lewis Street will be removed.

T3. *Confirm that the proposed configuration has been reviewed by the Town Fire Department.*

MPD: Noted

BETA2: BETA will defer this to the Board.

T4. *Provide details and grading for residential driveways. BETA notes that the “residential driveway” detail provided is for driveways with a grass strip and sidewalk that does not seem applicable to the Site.*

MPD: Based on site layout changes made in C-102 Layout and Materials Plan there are no longer “residential driveways” therefore the details and additional grading were not included.

BETA2: Design revised. Comment dismissed.

T5. *Confirm there is adequate maneuvering space for vehicles to exit the garages (20’ driveway aisle) and adequate turning radius for the largest vehicle anticipated on site, such as a waste collection or delivery.*

MPD: A vehicle turning analysis was completed and residential vehicles can exit all garages safely and both a pumper truck and garbage truck have adequate turning radius to safely maneuver on the site.

BETA2: BETA recommends that the garage space be shown for this analysis and that the results of the analysis be shown on the plans.

T6. *Depict existing sidewalk and Lewis Street edge of pavement on the plans.* MPD: Existing sidewalk on Lewis Street is shown in both the V-101 Existing Conditions and C-102 Layout and Materials Plan.

BETA2: Comment addressed.

T7. *Proposed curb ramp types should be designated on the plans.*

MPD: The curb ramp types are found on C-111 Construction Details and have been added to C-102 Layout and Materials Plan.

BETA2: Comment addressed.

PARKING AND LOADING

Required parking is defined by §185-21.B of the Town Zoning Bylaw. The proposed development includes residential and nonresidential uses in the Commercial I zoning district. Required parking is calculated as follows:

Use Designation	Criteria	# of Units / Building Area	Required Parking
-----------------	----------	----------------------------	------------------

Residential	1.5 spaces per residential unit	14 units	21 Spaces
Nonresidential	1 Space per 500 Sq. Ft. of gross floor area	406 Sq. Ft.	1 Spaces
Total			22 Spaces

The project proposes three (3) outdoor parking spaces and fourteen (14) garages. Based on the parking requirement table provided by the Applicant, each garage is intended to provided two parking spaces for a total of twenty-eight (28) residential parking spaces required.,

One (1) of the outdoor parking spaces is designed to be van accessible in accordance with 521 CMR 23.2.1

The one-way driveway is a minimum of 20-feet wide, increased to 30'± adjacent to the outdoor parking area. Commercial parking spaces are 9 feet wide; and 19 feet long. Residential driveways and garages are designated as 20.7' wide for driveways serving single units and 41.4' wide for driveways serving multiple units.

T8. Indicate location of door for commercial area and confirm there is adequate space for opening and maneuvering in accordance with applicable ADA regulations.

MPD: The location of the entrance to the commercial area has been added to C-102 Layout and Materials Plan and the building department will determine ADA regulation applicability.

BETA2: Information provided. BETA recommends for ADA applicability to be coordinated with the Building Commissioner during the design phase.

6.0 SIGNAGE AND LIGHTING

The project proposes two “visitor parking” signs at the northwest parking area. The project also proposes one accessible parking sign, a “one-way” sign, and a “do not enter” sign. All signs are anticipated to be appropriate for their use.

SL1. Provide detail for “visitor parking” sign. Provide detail or MUTCD reference for other proposed signs.

MPD: Detail for visitors parking sign is on sheet C-107 Construction Details.

BETA2: The detail has been provided on sheet C-109. Comment addressed.

SL2. Evaluate the placement of the “do not enter” sign and requirement for “one-way” signs per the MUTCD.

MPD: Noted

BETA2: Comment remains. BETA notes that “do not enter” signs are typically provided on both sides of the driveway and a “one way” sign on one side.

There is no indication in the planset that lighting is provided. The Illuminating Engineers Society of North America (IESNA) recommends the following illuminance for parking lots:

Level	Horizontal Illuminance (Min)	Vertical Illuminance (Min.)	Uniformity Ratio (Max/Min)
Basic Maintained Illuminance	0.2	0.1	20/1

Enhanced Security Illuminance	0.5	0.25	15/1
-------------------------------	-----	------	------

SL3. Clarify if site lighting is proposed. BETA recommends that lighting be provided to promote visitor and resident safety.

MPD: Scone lighting will be used to reduce potential disruption for abutting properties. A finalized lighting and photometric plan will be provided and added to the plan set at a later date.

BETA2: Lighting information will be reviewed upon receipt.

7.0 UTILITIES

Proposed utilities depicted on the plans include domestic water, fire service, sanitary sewer, electric service, and gas service.

Domestic water is proposed via new 2" copper type K and fire service is provided via new 4" CLDI. These services will connect to the existing main at East Central Street for Building "B" or the existing main at Lewis Street for Building "A". Additionally, new hydrants are proposed in the northeast and southeast corners of the Site.

Sanitary sewer service is proposed via new 6" PVC service. This service will connect to the existing main along the southern portion of the Site for Building "B" or the existing main at Lewis Street for Building "A".

Natural gas is proposed via a new service which will connect both buildings to the existing service at Lewis Street.

Electric service is proposed via new overhead line which will connect the Building "B" to an existing utility pole along East Central Street and Building "A" to an existing utility pole along Lewis Street.

U1. BETA defers to the preference of the Board on providing overhead or underground electric services.

MPD: Plans will reflect the Board's decision once made.

BETA2: BETA defers this item to the Board.

U2. Review design of southern drainage system. Two catch basins are proposed to be located directly over an existing sewer line to remain. This will impact the ability to repair or replace the sewer line in the future and there may direct conflict or adverse impacts from loading on the sewer line. Confirm legal right to place these structures within the easement.

MPD: The drainage layout has been updated on C-104 Utilities Plan to avoid these conflicts.

BETA2: The catch basins have been relocated outside the limits of the easement. Comment addressed.

U3. Provide detail for fire hydrant and associated gate valve.

MPD: The detail for the proposed fire hydrant and gate valve is on sheet C-107 Construction Detail.

BETA2: Comment addressed.

U4. Evaluate layout of fire protection service and route directly to sprinkler room, if required. MPD: The sprinkler room and water service to it is found on sheet C-102 Layout and Materials Plan by

Unit 14 in Building "A". **BETA2: Utility layout identified on Sheet C-104 for Building A only. BETA will defer this issue to the Fire Department.**

U5. *Confirm legal right to place a portion of the overhead electric line within the boundaries of the abutting property to the west.*

MPD: This is to be determined by the local power and light distributor in the area.

BETA2: Comment remains.

8.0 LANDSCAPE TREATMENT & GRADING

A landscaping plan has been provided depicting 75 shrub plantings and 2 tree plantings. Landscaping is generally proposed along the sidewalk, at the eastern driveways, and north of the outdoor parking area.

The project is not required to provide screening under §185-35.

Information on proposed seed mix for landscaping areas has not been provided.

LA1. *Confirm that proposed tree will not conflict with new overhead electric line.*

MPD: The placement of trees has been evaluated and should not conflict with overhead electric line.

BETA2: No further comment.

LA2. *Indicate treatment of existing trees along Lewis Street and depict location on the plans.*

MPD: The trees on Lewis Street were removed by the previous owner of the property.

BETA2: Information provided. Issue dismissed.

LA3. *Review grading in the northwest parking area. Based on the proposed spot grades and CB rim elevation this area is virtually flat and ponding/icing may result.*

MPD: Grading was reviewed to ensure positive grading and drainage in the northwest parking area.

BETA2: Based upon the spot grades shown on sheet C-103, the slope across the northwest parking lot is only 0.08% from the edge of the sidewalk to the catch basin. In addition, based upon the slope across the site BETA recommends that the garage locations including slab elevations be identified to show how they will relate to the proposed gutter line. Currently the proposed 283 & 284 contours between the buildings are each incorrect. Once garage slab elevations are identified, BETA also recommends that the first-floor elevations for each of the units be revisited.

LA4. *Indicate if any dumpsters or waste collection and disposal measures are proposed.*

MPD: There is no dumpster or waste collection because trash removal will be private collection.

BETA2: Comment remains. Explanation does not answer the issue of waste collection. If the waste collection is private collection than demonstrate pick up methodology since driveway is one way.

9.0 STORMWATER MANAGEMENT

The proposed stormwater management design consists of five subsurface infiltration systems located throughout the Site. The largest system is located beneath the central driveway and four smaller

systems are proposed on the eastern side of the Site. Stormwater runoff will be conveyed to the systems via a closed drainage system consisting of catch basins, manholes, “pretreatment” manholes, and roof leaders. The proposed design will rout stormwater runoff from Building B, a portion of Building A, and the central driveway to the larger system and stormwater runoff from the remainder of Building A and the residential driveways to the smaller systems. No means of conveying overflow has been incorporated into the system and thus in the event of overflow it is expected that the catch basins will surcharge and flood the immediate vicinity.

GENERAL

SW1. *Confirm that DMH-2 is properly sized to allow 4 pipe connections at the proposed pipe angles. A larger diameter structure may be required.*

MPD: DMH-2 will have an inner diameter of 60” to allow for all the pipe connections to be possible.

BETA2: Comment addressed.

STORMWATER MANAGEMENT REGULATIONS (CHAPTER 153)

The project proposes to disturb less than one acre within the Town of Franklin. It is therefore not subject to the Town of Franklin Stormwater Management Regulations.

MASSDEP REPORTABLE RELEASES

The MassDEP Waste Site / Reportable Release database identifies the abutting lot 244 East Central Street as the location of a reportable release under Release Tracking Number (RTN) 2-0016890. This MassDEP listed site adjoins the 240 East Central Street property. Available documentation indicates that the release originated from a crack in a copper line for an above-ground storage tank (AST) resulting in a release of #2 heating oil resulting in soil and groundwater impacts including the presence of light non-aqueous phase liquid (LNAPL) free project layer. Immediate Response Actions were conducted to remove impacted soil from the basement and install a polyethylene barrier around the release area. Further response actions included additional soil removal and subsurface investigations. The RTN has since been closed.

SW2. *Available documentation indicates a release of fuel oil on the abutting property that has impacted soil and groundwater. Recommend the Applicant have a qualified environmental professional evaluate if the infiltration basin could potentially exacerbate site conditions related to this release per stormwater Standard 3.*

MPD: Owner will take the necessary steps to ensure there is no impact to soil and groundwater.

BETA2: Comment remains. Explanation does not respond to the issue. LSP report should be provided.

MASSDEP STORMWATER STANDARDS

The project proposes to disturb less than one acre of land within the Town of Franklin and is not in proximity to wetland resources. Therefore, the project is only subject to Chapter 153 and the Massachusetts Stormwater Standards to the extent requested by the Board (185-31.C.(3)(m)). The following sections are provided for the Boards consideration. BETA notes that the Applicant has documented compliance with the MA Stormwater Standards in the Stormwater Management Report.

LOW IMPACT DEVELOPMENT (LID) TECHNIQUES

Proposed LID measures include no disturbance to any wetland resource area.

NO UNTREATED STORMWATER (STANDARD NUMBER 1): *No new stormwater conveyances (e.g., outfalls) may discharge untreated stormwater directly to or cause erosion in wetlands or waters of the Commonwealth.* The project does not propose any new discharges to wetlands - **complies with standard.**

SW3. *Indicate anticipated route for stormwater in the event of system overflow.*

MPD: Response: In the event of system overflow, the flow will be diverted back to the inlet pipe and discharge at the overflow located below the gutters, or will surcharge the upstream catch basin.

BETA2: It appears that Unit Nos. 8 & 14 may be flooded if the system overflows. BETA recommends that the overall grading be modified to ensure that the Lewis Street driveway entrance will act as the final overflow.

POST-DEVELOPMENT PEAK DISCHARGE RATES (STANDARD NUMBER 2): *Stormwater management systems must be designed so that post-development peak discharge rates do not exceed pre-development peak discharge rates.* The project proposes to mitigate increases to runoff rates with the use of subsurface infiltration systems. Calculations indicate a decrease in peak discharge rate and peak runoff volume to all points of analysis.

SW4. *Separate DP-1 into two analysis points: one for the East Central Street drainage system and one for the abutting property to the west.*

MPD: DP-1 was already divided to capture the changes associated with the new development.

BETA2: Comment remains, DP-1 is only one watershed and has not been divided. In addition, explain how runoff from the west side of Building will travel around Building B.

SW5. *Clarify routing for systems 1P and 12P. The model shows primary discharge through a 12" orifice to DP-3 and DP-2, respectively, but no orifices are depicted on the plans.*

MPD: Correct, the orifices represent entrances to the 12" HDPE pipes.

BETA2: Comment remains. There is no primary discharge from either of the two infiltration systems depicted on the plans or shown on the details. BETA recommends that this discharge capability be removed from the calculation.

SW6. *Review northern subcatchment boundary for P-2. It appears that the catchment area for CB-1 has been attributed to P-1, but this catch basin drains to the subsurface infiltration system.*

MPD: The orifices represent the entrance to the 12" HDPE pipes.

BETA2: No further comment.

SW7. *Provide spot grades at the residential driveway entrances to confirm whether offsite roadway flow will reach the proposed stormwater management system.*

MPD: Spot grades have been added to the C-103 Grading Plan.

BETA2: The driveway entrances from Lewis court have been removed from the design. Comment dismissed.

SW8. *Review HydroCAD model for subcatchment P-2:*

- a. *Confirm areas attributed to grass and paved parking.*
- b. *Revise time of concentration calculation to reflect the post-development site layout.*
MPD: Grass and paved areas have been confirmed and the time of concentration has been updated.

BETA2: Comment remains. There are no paved roads discharging towards DP P-3. The Tc calculation has not been corrected either. The maximum sheet flow length should be 50'. BETA recommends that the flow paths be identified on the watershed plans which support the calculations.

RECHARGE TO GROUNDWATER (STANDARD NUMBER 3): *Loss of annual recharge to groundwater should be minimized through the use of infiltration measures to maximum extent practicable.*

NRCS soil maps indicate that soils are Sudbury fine sandy loam with a hydrologic soil group rating (HSGR) of B (moderate infiltration potential) or urban land with no assigned HSGR. The Applicant has conducted two soil tests at the Site indicating the subsurface soils are predominantly loamy sand over fine sand. Groundwater was not detected in test pits to the bottom depth of 8' below grade.

Groundwater recharge is proposed via five new subsurface infiltration systems. The project is expected to provide a recharge volume in excess of what is required. Calculations have been provided indicating all BMPs will drawdown within 72 hours.

SW9. *Conduct test pits in the vicinity of the eastern subsurface systems to confirm suitability of this area for infiltration.*

MPD: Test pits were conducted on 5/22/24 in the footprint of the eastern stormwater system.

BETA2: Provide results of test pit information.

SW10. *Revise system bottoms for subsurface infiltration systems to provide at least 2' separation to groundwater. Test Pits 1 and 2 were completed to a depth of 8' below grade, or approximate elevation 275', while the system bottom elevation is 276.48'. As groundwater was not encountered, elevation 275' should be assumed to be the estimated seasonal high groundwater elevation. It is BETA's understanding that groundwater was encountered several feet below the system bottom on the adjacent 230 East Central Site during construction.*

MPD: Test pits were conducted in the footprint of the western stormwater system again to confirm ESHWT which was approximately 13' below grade.

BETA2: Provide updated test pit information. The test pit data shown on Sheet V-1 does not confirm that the depth of the excavation extended to 13' and there is no other test pit data provided.

SW11. *Provide required mounding analysis where infiltration BMPs have less than 4 feet of separation to estimated seasonal high groundwater.*

MPD: A mounding analysis has been completed and can be found in the Stormwater Report under Appendix C entitled Subsurface Exploration Data.

BETA2: Mounding analysis has been provided however results for system 2 shows a 4.31' mound which far exceeds the 1.48' separation documented by the test pit data. BETA recommends that the designer review the overall recharge volume considered in each of the

analyses and clarify the initial saturated thickness, which appears to be the depth to groundwater rather than thickness of the aquifer. If updated test pit data confirms greater than 4' of separation to groundwater is provided, the mounding analysis may no longer be necessary.

SW12. *A setback of at least 10 feet from property lines and buildings for all SCMs is typically required per (MA Handbook V1C1 Pg 8). Coordinate with the DPW to determine if any impacts to the roadway subgrade will result from installation of the subsurface systems.*

MPD: We will coordinate with the DPW to inquire about any impacts to the roadway with the subsurface systems.

BETA2: BETA will defer this issue to the DPW and notes the current setback is approximately 8 feet.

SW13. *Confirm that the infiltration of stormwater in close proximity to building foundations will not impair the stability of the proposed buildings or #244 East Central Street. Consider providing an impermeable liner between the proposed infiltration system and the #244 property if necessary.*

MPD: According to MASSDEP Volume 2 Chapter 2 infiltration practices need to be at least 10' from building foundations.

BETA2: Comment remains. In accordance with Volume 1, Chapter 1 setbacks range from 10-100'. Since system for pond 12P is between the buildings an impermeable liner should be considered.

TOTAL SUSPENDED SOLIDS (STANDARD NUMBER 4): For new development, stormwater management systems must be designed to remove 80% of the annual load of Total Suspended Solids (TSS).

The project includes the following treatment trains:

Treatment Train	SCM 1	SCM 2	Infiltration BMP	TSS Removal %
A	Deep Sump Catch Basin	"Pretreatment Manhole"	Subsurface Infiltration System	80%
B	Deep Sump Catch Basin	None	Subsurface Infiltration System	80%

The project has been designed to provide at least 80% TSS removal for treated impervious areas. The proposed infiltration BMP has been sized to treat the required 1-inch water quality volume.

Per Standard 6, the project is required to provide at least 44% TSS removal as pretreatment. Pretreatment for the large system is provided via deep-sump catch basins and deep-sump manholes identified as "pretreatment manholes." Pretreatment for the smaller systems is provided via deep-sump catch basins and isolator row.

A Long Term Pollution Prevention Plan is included in the O&M Plan.

SW14. *Provide required 44% pretreatment for infiltration structures. Per V1C1 Page 11 of the MA Stormwater Handbook, the 25% TSS removal for deep-sump catch basins is provided only if the structure is off-line. The pretreatment manholes are in-line and therefore do not provide any*

additional pretreatment. Additionally, no secondary pretreatment SCM has been provided for the eastern subsurface infiltration systems.

MPD: A second TSS removal sheet has been added to Appendix I entitled TSS Removal Calculations has been added to address the concerns mentioned above.

BETA2: Comment remains. The pretreatment manhole is still in-line and therefore is not entitled to a 25% TSS Removal rate.

SW15. *Clarify if additional pretreatment is to be provided within the Chambermaxx retention system with the “containment row” options.*

MPD: A new design for this treatment train has been provided and it only includes rooftop runoff which does not require pretreatment.

BETA2: Comment remains. BETA agrees that for system 1 roof runoff does not require pretreatment. However, the question remains is additional pretreatment to be provided by the containment row? If yes than the TSS Removal calculations should be modified accordingly.

SW16. *Remove pretreatment devices from TSS worksheet for total TSS; the 80% TSS provided by the subsurface system is inclusive of required pretreatment.*

MPD: A second TSS removal sheet has been added to Appendix I entitled TSS Removal Calculations has been added to address the concerns mentioned above.

BETA2: Comment remains. Calculations have not been corrected.

HIGHER POTENTIAL POLLUTANT LOADS (STANDARD NUMBER 5): *Stormwater discharges from Land Uses with Higher Potential Pollutant Loads (LUHPPLs) require the use of specific stormwater management BMPs.*

The project includes residential and commercial uses which are not typically considered LUHPPLs – **standard not applicable.**

CRITICAL AREAS (STANDARD NUMBER 6): *Stormwater discharges to critical areas must utilize certain stormwater management BMPs approved for critical areas.*

A portion of the site is located within a MassDEP mapped wellhead protection area – Zone II which is a critical area. The project is required to treat the 1-inch water quality volume and provide at least 44% pretreatment for infiltration SCMs. Subsurface structures are considered suitable SCMs for use in Zone II wellhead protection areas.

REDEVELOPMENT (STANDARD NUMBER 7): *Redevelopment of previously developed sites must meet the Stormwater Management Standards to the maximum extent practicable.*

The project does not qualify as a redevelopment – **standard not applicable.**

EROSION AND SEDIMENT CONTROLS (STANDARD NUMBER 8): *Erosion and sediment controls must be implemented to prevent impacts during construction or land disturbance activities. As the project proposes to disturb less than one acre of land, it will not be required to file a Notice of Intent with EPA nor develop a Stormwater Pollution Prevention Plan (SWPPP). An erosion control plan has been provided showing inlet protection, linear sedimentation control (compost filter sock), and designated stockpile locations with perimeter controls. A basic construction sequence is outlined on the plans.*

SW17. *Provide callout for the two stone hatched areas on Sheet C-101, presumed to be anti-tracking pads. Provide detail as applicable.*

MPD: The callout for both hatched areas has been provided on sheet C-101 Demolition, Erosion and Sediment Control Plan

BETA2: Detail has not been provided as requested.

SW18. *Clarify proposed construction sequence as it relates to construction entrance location during demolition. The northern anti-tracking pad overlaps with the existing northern building.*

MPD: The house has been demolished and therefore the tracking pads are in the correct location.

BETA2: Information provided. Comment addressed.

SW19. *Clearly indicate inlet protection will be provided at all new catch basins until the Site is fully stabilized. In coordination with the DPW provide inlet protection at existing catch basins adjacent to the site on East Central Street and Lewis Street.*

MPD: Inlet protection has been added to sheet C-101 Erosion and Sediment Control plan.

BETA2: Silt sacks have been depicted; however, it is not clear that they are associated with proposed catchment structures and are not coincident with the revised location of structures shown on Sheet C-104. Also, no inlet protection is called out on Sheet C-101 for the existing catch basins in Lewis Street.

OPERATIONS/MAINTENANCE PLAN (STANDARD NUMBER 9): *A Long-Term Operation and Maintenance Plan shall be developed and implemented to ensure that stormwater management systems function as designed. A Stormwater Operation and Maintenance Manual was provided with the Stormwater Management Report.*

SW20. *Provide map, drawn to scale, that shows the location of all stormwater BMPs in each treatment train and snow storage areas.*

MPD: BMP treatment trains are displayed on the C-103 Grading Plan and C-104 Utility Plans.

BETA2: Comment remains. Plan is required as part of O & M Plan.

SW21. *Provide approximate annual maintenance budget.*

MPD: This is provided in the Stormwater Report under Appendix J entitled Long-Term Pollution Prevention And Stormwater Operation & Maintenance Plan.

BETA2: Comment addressed.

SW22. *Provide signature of owner on the O&M Plan.*

MPD: This is provided in the Stormwater Report under Appendix J entitled Long-Term Pollution Prevention And Stormwater Operation & Maintenance Plan.

BETA2: Comment remains. Signature not provided.

ILLICIT DISCHARGES (STANDARD NUMBER 10): *All illicit discharges to the stormwater management system are prohibited. A signed Illicit Discharge Compliance Statement was provided with the submission.*

240 East Central Street
May 30, 2024
Page 16 of 16

If we can be of any further assistance regarding this matter, please contact us at our office.

Very truly yours,
BETA Group, Inc.



Stephen Borgatti, PE, MENG
Senior Project Engineer



Matthew J. Crowley, PE
Senior Project Manager