



Symbol	Label	Qty	Part Number	Arrangement	LLF	Total Watts	Total Luminaire Lumens	BUG Rating
PM-T4L	PM-T4L	21	Visionaire # VSK-11-T4L-10L-4K-UNV-SAR-BK	Single	0.950	70	2956	B0-U3-G3
PM-TSR	PM-TSR	1	Visionaire # VSK-11-TSR-10L-4K-UNV-SAR-BK	Single	0.950	70	9356	B3-U0-G3
WM-1	WM-1	7	Visionaire # VSK-11-T3-16LC-3-4K-UNV-WM-BK	Single	0.950	18	2355	B1-U0-G1
WM-2	WM-2	20	Visionaire # VSK-11-T3-16LC-3-4K-UNV-WM-BK	Single	0.950	52	6364	B2-U0-G2
WM-3	WM-3	3	Visionaire # VSK-11-T2-16LC-3-4K-UNV-WM-BK	Single	0.950	18	2337	B1-U0-G1

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Overall Site Points	Illuminance	FC	1.25	9.8	0.0	N.A.	N.A.
Property Line	Illuminance	FC	0.07	1.1	0.0	N.A.	N.A.

- NOTES:**
- A. A LIGHT LOSS FACTOR OF 0.950 HAS BEEN APPLIED TO FIXTURES UNLESS OTHERWISE NOTED. REFER TO LUMINAIRE SCHEDULE FOR LIGHT LOSS FACTOR AND LUMEN INFORMATION.
 - B. SEE "MH" ON LIGHTING FIXTURE TAG LOCATED ON PLAN FOR MOUNTING HEIGHT INFORMATION.
 - C. CALCULATION POINTS ARE TAKEN AT GRADE.
 - D. CALCULATION RESULTS ARE BASED ON IES STANDARDS UNLESS OTHERWISE REQUESTED.
 - E. BASIS OF DESIGN PROVIDED BY SK & ASSOCIATES. FOR FURTHER INFORMATION, PLEASE CONTACT MAIN OFFICE AT (781) 821-1700.

PROJECT:
60 Earls Way - Site
Site Lighting Plan, Photometrics & Schedules

CONTACT:
Howard Dalton
Principal
(774) 281-3754
hdalton@sk-associ.com

PROJECT NUMBER: ---
DATE: April 1, 2025
REVISION: ---
SCALE: As Noted
DRAWING BY: AD **CHECKED BY:** HD
DRAWING NUMBER:

SK & Associates
Experience the light™
CT | MA | ME | NH | RI | VT
20 Carver Circle
Canton, MA 02021
(781) 821-1700

PREPARED FOR:
United Consultants

SL1