



- Smoke Alarms**
 - One smoke alarm on every habitable level of the residence
 - One smoke alarm at the base of each stairwell.
 - One smoke alarm inside of each separate sleeping area.
 - A minimum of one smoke alarm must be installed every 1,200 square feet of living space per level.
 - Must be hardwired and interconnected with battery backup.
 - All smoke alarms must be photosensitive
- Carbon Monoxide Alarms**
 - One on every level of the residence including basements and habitable portions of attics, and must be within 10 feet of each bedroom door.
 - Combination alarms (photoelectric and carbon alarm) may be used.
 - Must be hardwired and interconnected with battery backup. (May be separately hardwired from the existing smoke detection system.)
- Heat Alarms**
 - Must have single heat alarm in any garage attached to or under the residence.
 - Must be hardwired and interconnected with or without battery backup to existing smoke detection system.

PROJECT:
OSBOURNE

PROJECT # 22051

CREATIVE DESIGNS
BY SCOTT RAPOZA

785 PINE AVENUE AT TLEBORO, MA
P. 508-509-5114
scott@creativedesignsma.com

OSBOURNE RENOVATIONS
33 UNCAS BROOK ROAD
FRANKLIN, MA

ISSUE	DATE
PRELIMINARY PLANS	07-01-2022
ISSUE FOR PERMIT	09-26-2022

DRAWING SCALE: NTS

DRAWN BY: SPR CHECKED BY: _____

DRAWN TITLE:
PROPOSED FLOOR PLANS
PROPOSED FOUNDATION PLAN
DETAILS

DRAWING NUMBER:
A1.0